

May 6, 1993



DIVISION OF OUL GAS & MINIMO

Mr. Don Ostler, Director State of Utah Division of Water Quality Department of Environmental Quality Salt Lake City, Utah 84114-4870

Dear Mr. Ostler:

RE: NPDES PERMIT UT-0023540

In accordance with conditions of NPDES Discharge Permit UT-0023540, Part II - I-3 and Utah Coal Mining Rules R645-301-731.223, Utah Fuel Company is herewith providing the required written notification of a failure to comply with the maximum effluent limitations for TDS and oil and grease at the 001 discharge point.

The problem occurred with the sample taken April 27, 1993, which had a TDS concentration of 1053 mg/l. This concentration exceeds the 1000 mg/l maximum limitation for TDS established in the current NPDES discharge permit. The oil and grease concentration was 14.4 mg/l which exceeds the daily maximum limitation of 10 mg/l. The laboratory report was received on May 5, 1993.

Sincerely,

Keith W. Welch

Kerth to Werch

Environmental Coordinator

KWW/gb/423

cc: Division of Oil, Gas & Mining
Glen A. Zumwalt
Keith Zobell
Michael Reed, EPA
Ken May

Craig Hilton